TO: Bidders of Record

FROM: EA Engineering, Science, and Technology Inc., P.B.C.

11202 Racetrack Road

Unit 103

Ocean Pines, MD 21811

RE: Addendum No. 2

Town of Berlin Branch Street Well House Emergency Generator

Berlin, MD

TO ALL BIDDERS: This Addendum No. 2 contains direction for modification to Contract Documents. This Addendum No. 2 shall supplement, amend, and become part of the Contract Documents and Construction Specifications for the title project and contract. All bids shall be based on this addendum in accordance with the Bidding Documents.

This Addendum contains the following:

• Contract Document Clarifications

CONTRACT DOCUMENT CLARIFICATIONS

- 1. ADD Figure 1 "Building Plan"
- 2. ADD Figure 2 "One-Line Diagram"
- 3. In Section 26 32 13, Emergency Generator, revise the section as follows: .
 - a. In article 2.7.B, DELETE "Silencers shall be of the residential type, .." and SUBSTITUTE "Silencers shall be Critical Grade.."
 - b. In article 2.8.A, DELETE "600 gallons" and SUBSTITUTE "475 gallons"
 - c. In article 3.2.D.3, DELETE "Continue this test for 5 hours..." and SUBSTITUTE "Continue this test for 2 hours..."
 - d. In article 3.2.D.4, DELETE "Then apply full rated load for four hours..." and SUBSTITUTE "Then apply full rated load for two hours...".

